



PBS Number
4-600064

New York State Department of Environmental Conservation
PETROLEUM BULK STORAGE CERTIFICATE

625 Broadway, 11th Floor, Albany, NY 12233-7020 Phone: 518-402-9553

Region 4 NYSDEC - PBS Unit
1130 North Westcott Road
Schenectady, NY 12306
(518) 357-2045

<u>TANK NUMBER</u>	<u>TANK LOCATION</u>	<u>DATE INSTALLED</u>	<u>TANK TYPE</u>	<u>PRODUCT STORED</u>	<u>CAPACITY (GALLONS)</u>	<u>DATE LAST TESTED</u>	<u>TESTING DUE DATE</u>
1	Aboveground - in contact with soil	11/01/1992	Steel/Carbon Steel/Iron	Diesel	4,000		*
2	Aboveground - in contact with soil	01/01/1992	Steel/Carbon Steel/Iron	#2 Fuel Oil	1,000		*
3	Aboveground - in contact with soil	11/01/1986	Steel/Carbon Steel/Iron	#2 Fuel Oil	550		*
4	Aboveground - in contact with soil	11/01/1992	Steel/Carbon Steel/Iron	#2 Fuel Oil	500		*
5	Aboveground - in contact with soil	11/01/1986	Steel/Carbon Steel/Iron	Gasoline	2,000		*
6	Aboveground - in contact with soil	10/01/1993	Steel/Carbon Steel/Iron	Used Oil (Heating)	300		*
7	Aboveground - in contact with soil	11/01/1995	Steel/Carbon Steel/Iron	Lube Oil	200		*
8	Aboveground - in contact with soil	11/01/1997	Steel/Carbon Steel/Iron	#2 Fuel Oil	275		*

* Aboveground tanks require monthly visual inspections and may need documented internal inspections as described in 6 NYCRR Part 613

OWNER:
TOWN OF CAIRO HIGHWAY DEPT.
ROUTE 145
CAIRO, NY 12413

SITE:
TOWN OF CAIRO HIGHWAY DEPT.
ROUTE 145
CAIRO, NY 12413

ON-SITE OPERATOR: ROBERT F. HEMPSTEAD
(518) 622-9515
PRIMARY OPERATOR:
EMERGENCY OPERATOR: ROBERT F. HEMPSTEAD
CONTACT: (518) 622-9515

ISSUED BY: Commissioner
Joe Martens
PBS NUMBER: 4-600064
DATE ISSUED: 05/21/2012
EXPIRATION DATE: 02/04/2017
FEE PAID: \$500.00

MAILING CORRESPONDENCE:

ROBERT F. HEMPSTEAD
TOWN OF CAIRO
PO BOX 728
CAIRO, NY 12413

As an authorized representative of the above named facility, I affirm under penalty of perjury that the information displayed on this form is correct to the best of my knowledge. Additionally, I recognize that I am responsible for assuring that this facility is in compliance with all sections of 6 NYCRR Parts 612, 613 and 614, and applicable sections of 6 NYCRR Subpart 374-2 (used oil tanks only), not just those cited below:
-- The facility must be re-registered if there is a transfer of ownership.
-- The Department must be notified within 30 days prior to adding, replacing, reconditioning, or permanently closing a stationary tank.
-- The facility must be operated in accordance with the code for storing petroleum, 6NYCRR Part 613.
-- Any new facility or substantially modified facility must comply with 6NYCRR Part 614.
-- **This certificate must be signed and posted on the premises at all times.** Posting must be at the tank, at the entrance of the facility, or the main office where the storage tanks are located.
-- Any person with knowledge of a spill, leak or discharge must report the incident to DEC within two hours (1-800-457-7362).

Signature of Representative/ Owner

Date

Name and Title of Authorized Representative/Owner (Please Print)